



OFFICE OF RAIL REGULATION

Notice 300399370 served against Ian Farmer Associates (1998) Limited on 11/09/2006

Notice type	Improvement Notice
Summary	Failure to co operate with other employers sharing a workplace at Reading Power Signal Box including Network Rail Infrastructure Ltd. Failure to take all reasonable steps to co-ordinate measures required to comply with the relevant statutory provisions in respect of the risk of contact with buried services including high energy (11kv) cable.
Recipient details	Ian Farmer Associates (1998) Ltd Unit 1 Bamburgh Court Team Valley Trading Estate Gateshead NE11 OTX
Compliance date	13/11/2006
	Revised compliance date
Breaches involved in this Notice	Health and Safety at Work Act 1974. Section 3(1). Electricity at Work Regulations 1989. Regulation 4(3) Management of Health and Safety at Work Regulations 1999. Regulation 11.
Location of offence	
Address	Reading Power Signal Box
ORR details	
ORR Area Team	Western
ORR Directorate	Railway Inspectorate